



SUPERINTENDENCE COMPANY OF INDIA PRIVATE LIMITED

LABORATORY :

PLOT NO. Y-23, BLOCK-EP, SECTOR-V, SALT LAKE CITY, KOLKATA-700 091
© : (033) 2357-4671/ 4681 / 5039 / 5042 • Fax : (033) 2357- 4806

E-mail : supind2019@gmail.com / supind50@yahoo.co.in
Website : www.superintendencecoindia.com

GSTIN : 19AAECS3740C2ZJ



(An ISO 9001 : 2015 Certified)



TC-8066

TEST REPORT

Form No: SUP/T/7.8/F1
Issue date : 06.02.2019
Amend-I dt. 02.05.2019

Page - 1/1

Name & Address of Customer

: NABA DIGANTA WATER MANAGEMENT LIMITED
(A JOINT VENTURE OF TATA STEEL UISL AND VOLTAS)
GN 11-19, SECTOR -V, SALT LAKE,
KOLKATA - 700 091

Sample forwarding W.O. No & Date

: 4600000013/CPG

Date of Sample receipt

: 23.05.2025

Dated : 22.05.2025

Test Performed On

: 23.05.2025 to 03.06.2025

Material

: Drinking Water. [Location : NDITA Town Hall (EP-DIA) Sec-V, Salt Lake, Kol-91]

ULR-TC806625000001193F

Test Report No.

: N-0459

Dt: 03.06.2025

I. Chemical Testing

1. Water

DRINKING WATER AS PER IS : 10500 / 2012

Sl. No.	Specific Test Performed	Requirement		Test Method Specification against which tests are performed	Test Results
		Acceptable Limit	Permissible Limit		
1.	pH at 25°C	6.5 to 8.5	No Relaxation	IS: 3025 (Pt-11)	8.05
2.	Turbidity (NTU)	1	5	IS: 3025 (Pt-10)	< 1.0
3.	Residual, Free Chlorine (mg/l)	0.2	1	IS: 3025 (Pt-26)	0.1
4.	Total Hardness (as CaCO ₃) (mg/l)	200	600	APHA (24 th Edn.) 2340 C,	131
5.	Iron as Fe (mg/l)	0.3	No Relaxation	APHA (24 th Edn.) 3111 B,	0.208
6.	Total Dissolved Solids (mg/l)	500	2000	IS : 3025 (Part-16)	200
7.	Arsenic as As (mg/l)	0.01	0.05	APHA (24 th Edn.) 3120 B	< 0.05

Tested By :

P. BHATTACHARJEE

P. BHATTACHARJEE

Authorised Signatory

P. DUTTA

P. DUTTA
(Technical Manager)

END OF THE REPORT

- Note : 1) This report refers to the values obtained at the time of testing and results relate to the items tested.
2) This Report shall not be reproduced in part or full without written permission of the management.
3) Liability for return of samples ceases after 15 days from the date of test report.



SUPERINTENDENCE COMPANY OF INDIA PRIVATE LIMITED

LABORATORY :

PLOT NO. Y-23, BLOCK-EP, SECTOR-V, SALT LAKE CITY, KOLKATA-700 091

☎ : (033) 2357-4671 / 4681 / 5039 / 5042 • Fax : (033) 2357- 4806

E-mail : supind2019@gmail.com / supind50@yahoo.co.in

Website : www.superintendencecoindia.com

GSTIN : 19AAECS3740C2ZJ



(An ISO 9001 : 2015 Certified)

TEST REPORT

Page - 2/2

Test Report No.

: N-0459

Dt: 03.06.2025

II. Biological Testing

2. Water

TEST RESULT OF BACTERIOLOGICAL

Sl. No.	Specific Test Performed	Test Method Specification against which tests are performed	Permissible Limits	Test Results
1.	Coliform Organism per 100 ml.	Specification as per IS: 10500 - 2012 and	Shall not be detected in 100 ml. sample	Not Detectable
2.	E. Coli per 100 ml.	Method as per IS: 1622 - 81	Shall not be detected in 100 ml. sample	Not Detectable

Tested By :


H. Roy

Authorised Signatory


A. Das

END OF THE REPORT

Note : 1) This report refers to the values obtained at the time of testing and results relate to the items tested.
2) This Report shall not be reproduced in part or full without written permission of the management.
3) Liability for return of samples ceases after 15 days from the date of test report.