



# R. V. BRIGGS & CO. PRIVATE LTD.

ANALYTICAL CONSULTING & TECHNICAL CHEMISTS

(AN ISO 9001:2015 & ISO 45001 : 2018 CERTIFIED COMPANY)

TAHER MANSION, 1ST FLOOR

9, BENTINCK STREET, KOLKATA - 700 001

Phone : (033) 4044-3380 / 3381 / 3382 / 3383, Website : www.rvbriggs.com

E-mail : rvbriggs.kolkata@gmail.com, info@rvbriggs.com

CIN : U51109WB1931PTC007007



TC-12347

## TEST REPORT

Certificate No.E(D)/25-26/2354

Issue Date: 28 March 2026

Page 1 of 2

Issued to	: M/s. NABA DIGANTA WATER MANAGEMENT LTD. (A Joint Venture of Tata Steel Utilities & Infrastructure Services Ltd., & Voltas) GN-11-19, Sector-V, Salt Lake, Kolkata-700091		
Your Ref. No.	: PO No.: 4600000026		
Description of Sample	: Effluent		
Sample ID No	: E(D)/25-26/2354		
Name of Industries / Site	: Naba Diganta Water Management Ltd. GN-11-19, Sector-V, Salt Lake, Kolkata-700091		
Collection Source	: 8.3 MLD STP Outlet		
Sample Drawn by us on	: 24.03.2026 at 12:35 P.M.		
Sample Carried out by	: Mr. P.Paul		
Sampling Plan	: RVB/FM/45		
Analysis Started on	: 24.03.2026	<b>Parameter Tested:</b>	
Analysis completed on	: 28.03.2026	pH, TSS, O & G, BOD, COD, AN, TKN & P	
Sample collection Procedure	: APHA 24th Edition 1060		
Mode of Sampling	: Grab		
Environmental condition during sampling	: Temperature : 32°C, Transported in Ice box, Cold chain maintained		

### TEST FINDINGS:

Sl. No.	Test Parameters	Test Method	Unit	Results	Limit as per Environmental Protection Act, MOE & F for Effluent discharged into Inland surface water
1	pH Value	APHA 24th edition 4500 -H +B	..	7.34	5.5 – 9.0
2	Total Suspended solids (TSS)	APHA 24th edition 2540D	mg/l	9	100 (Max.)
3	Oil and Grease (O & G)	APHA 24th edition 5520B	mg/l	< 2	10 (Max.)
4	Biochemical Oxygen Demand for 3 days at 27°C (BOD)	I.S. 3025 (Part – 44) – 2023	mg/l	3.3	30 (Max.)
5	Chemical Oxygen Demand (COD)	APHA 24th edition 5220B	mg/l	12	250 (Max.)
6	Ammoniacal Nitrogen (AN)as N	APHA 24th edition 4500 NH3 F	mg/l	0.400	50 (Max.)
7	Total Kjeldahl Nitrogen (TKN) as N	APHA 24th edition 4500-Norg B	mg/l	0.598	100 (Max.)
8	Total Phosphate as P	APHA 24th edition 4500F-PD	mg/l	0.101	5.0 (Max.)

Remarks: The sample of Effluent complies with Environmental Protection Act, MOE & F for effluent discharged into Inland Surface water in respect of above mentioned parameters.

Note: Minimum Detection Limit of O & G .. 2 mg/l.

Report Verified by

Reviewed & Authorised by

(J.Das)

Dy. Technical Manager  
Authorised Signatory

For R.V. BRIGGS & CO. (P) LTD.

-: END OF TEST REPORT:-

- ★ The test report shall not be reproduced, except in full, without written approval of the Company.
- ★ Results relate only to the parameters of the item tested.



# R. V. BRIGGS & CO. PRIVATE LTD.

**ANALYTICAL CONSULTING & TECHNICAL CHEMISTS**

**(AN ISO 9001:2015 & ISO 45001 : 2018 CERTIFIED COMPANY)**

TAHER MANSION, 1ST FLOOR

9, BENTINCK STREET, KOLKATA - 700 001

Phone : (033) 4044-3380 / 3381 / 3382 / 3383, Website : www.rvbriggs.com

E-mail : rvbriggs.kolkata@gmail.com, info@rvbriggs.com

CIN : U51109WB1931PTC007007



TC-12347

## TEST REPORT

**Certificate No.E(D)/25-26/2354**

**Issue Date: 28 March 2026**

**Page 2 of 2**

Issued to	: M/s. NABA DIGANTA WATER MANAGEMENT LTD. (A Joint Venture of Tata Steel Utilities & Infrastructure)	
Your Ref. No.	: PO No.: 4600000026	
Description of Sample	: Effluent	
Sample ID No	: E(D)/25-26/2354	
Name of Industries / Site	: Naba Diganta Water Management Ltd. GN-11-19, Sector-V, Salt Lake, Kolkata-700091	
Collection Source	: 8.3 MLD STP Outlet	
Sample Drawn by us on	: 24.03.2026 at 12:35 P.M.	
Sample Carried out by	: Mr. P.Paul	
Sampling Plan	: RVB/FM/45	
Analysis Started on	: 24.03.2026	<b>Parameter Tested:</b> Microbiological: Faecal Coliform
Analysis Completed on	: 26.03.2026	
Sample collection Procedure	: APHA 24th Edition 9060	
Mode of Sampling	: Grab	
Environmental condition during sampling	: Temperature : 32°C, Transported in Ice box, Cold chain maintained	

### **MICROBIOLOGICAL TEST FINDINGS:**

Sl. No.	Test Parameters	Test Method	Unit	Results	Limit as per Environmental Protection Act, MOE & F for Effluent discharged
1	Faecal Coliform	APHA 24th Edition 9221E	MPN/ 100 ml.	< 2	1000 (Max.)

Remarks: The sample of Effluent complies with Environmental Protection Act, MOE & F for effluent discharged in respect of above mentioned parameter.

Report Verified by

Reviewed & Authorised by

( Pijush Kanti Dutta )

Sr. Microbiologist

Authorised Signatory

For R.V. BRIGGS & CO. (P) LTD.

**-: END OF TEST REPORT:-**

- ★ The test report shall not be reproduced, except in full, without written approval of the Company.
- ★ Results relate only to the parameters of the item tested.